

16. All correspondence sent to the District regarding this permit must include the permit number **(2-001-218914-3)**.
17. The District reserves the right to open this permit, following notice to the permittee, to include a permit condition prohibiting withdrawals for resource protection.
18. The lowest quality water source, such as reclaimed water or surface water, shall be used in lieu of groundwater at this project when technically, economically, and environmentally feasible.
19. The permittee shall implement and/or maintain the conservation practices selected in the Water Conservation Plan submitted to the District. Any new practices selected shall be implemented within one year from the date of permit issuance. Practices that involve scheduling methods or maintenance shall be documented. Documentation for implementation and/or maintenance shall be maintained on all practices and available upon request.
20. The permittee's water use shall be consistent with the MFL prevention or recovery strategy developed for any water body from which this permitted water use directly or indirectly withdraws or diverts water, pursuant to subsection 40B-2.301(2)(h), F.A.C.
21. Following the effective date of the re-evaluated Minimum Flows and Levels adopted pursuant to subsection 62-42.300(1)(e), F.A.C., this permit is subject to modification during the term of the permit, upon reasonable notice by the District to the permittee, to achieve compliance with any approved MFL recovery or prevention strategy for the Lower Santa Fe River, Ichetucknee River, and Associated Priority Springs. Nothing herein shall be construed to alter the District's authority to modify a permit under circumstances not addressed in this condition.
22. Total withdrawal from wells 1 (Station ID 157272), and 2 (Station ID 157273), and the irrigation pump (Station ID 157275) must be recorded continuously, totaled monthly, and reported to the District at least every six months for the duration of this permit using Water Use Pumpage Report Form (EN-50). The meter reading or quantity withdrawn must be reported in gallons and should be submitted on-line at <https://permitting.sjrwmd.com/srep/#/ep> whenever possible. Reporting is required, even if there is no use.

The reporting dates each year will be as follows:

Reporting Period	Report Due Date
January - June	July 31
July - December	January 31

23. The permittee shall maintain all totalizing flow meters. In case of failure or breakdown of any meter, the District shall be notified in writing within five days of its discovery. A defective meter shall be repaired or replaced within 30 days of its discovery.
24. The permittee shall have all flow meters checked for accuracy once every five years within 30 days of the anniversary date of the issuance of this permit. The meters must be recalibrated if the difference between the actual flow and the meter is greater than five percent.
25. The permittee shall perform a water audit of the golf course irrigation system in year 2029 or 2030 and provide the results of the audit by April 8, 2030, or upon permit renewal, whichever is sooner. The water audit shall include at a minimum: