

<u>Date</u>	<u>Monitoring Location</u>	<u>Description</u>	<u>Result</u>	<u>Limit</u>	<u>Units</u>	<u>Statistical Base</u>
12/31/2024	EFD-1	Cyanide, Total (as CN)	2.1	1.0	µg/L	Maximum
04/30/2019	EFD-1	Cyanide, Total (as CN)	5.5	1.0	µg/L	Maximum

c) Permit Condition 1.A.1 “Effluent Limitations and Monitoring Requirements, Surface Water Discharges,” sets effluent limitations for Fecal Coliform, Enterococci, and Ultraviolet Light Dosage. These limits were not met as shown in the Table below:

**Table 3: Fecal Coliform, Enterococci, and Ultraviolet Light Dosage**

<u>Date</u>	<u>Monitoring Location</u>	<u>Description</u>	<u>Result</u>	<u>Limit</u>	<u>Units</u>	<u>Statistical Base</u>
09/30/2024	EFF-1	Ultraviolet Light Dosage	2.53	25	mW-s/sqcm	Minimum
07/31/2024	EFF-1	Ultraviolet Light Dosage	2.81	25	mW-s/sqcm	Minimum
02/29/2024	EFF-1	Ultraviolet Light Dosage	0	25	mW-s/sqcm	Minimum
12/31/2023	EFF-1	Ultraviolet Light Dosage	1.31	25	mW-s/sqcm	Minimum
09/30/2023	EFF-1	Ultraviolet Light Dosage	13.26	25	mW-s/sqcm	Minimum
07/31/2023	EFF-1	Ultraviolet Light Dosage	14.6	25	mW-s/sqcm	Minimum